

**CERTIFICATE OF ANALYSIS**

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ 07452

Project ID : Marion P. Thomas Elementary Building A #6712
PAS Project ID : P17-1634

Matrix : Drinking Water
Report Date : 4/25/2017

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P17-1634-01	MEA-B-S-01A	Lead	16.0	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/8/17 07:39	4/18/17 16:21
P17-1634-02	MEA-1-WC-01A	Lead	ND	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/8/17 07:44	4/18/17 16:29
P17-1634-03	MEA-2-WC-02A	Lead	ND	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/8/17 07:45	4/18/17 16:46
P17-1634-04	MEA-2-S-02A	Lead	4.50	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/8/17 07:47	4/18/17 16:50
P17-1634-05	MEA-4-8-FB-A	Lead	ND	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/8/17 07:48	4/18/17 16:54

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director