



CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ 07452

Project ID : Marion P. Thomas Elementary Building B #6712
PAS Project ID : P17-1635

Matrix : Drinking Water
Report Date : 4/25/2017

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P17-1635-01	MEB-B-S-01A	Lead	15.5	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/8/17 07:52	4/18/17 17:06
P17-1635-02	MEB-1-S-02A	Lead	11.5	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/8/17 07:56	4/18/17 17:10
P17-1635-03	MEB-1-WC-01A	Lead	5.84	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/8/17 07:55	4/18/17 17:14
P17-1635-04	MEB-2-WC-02A	Lead	6.64	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/8/17 07:59	4/18/17 17:19
P17-1635-05	MEB-4-8-FB-A	Lead	ND	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/8/17 08:16	4/18/17 17:23

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director