

**CERTIFICATE OF ANALYSIS**

**Customer :** Garden State Environmental  
555 South Broad Street, Suite K  
Glen Rock, NJ 07452

**Project ID :** Marion P. Thomas Elementary Building C #6712  
**PAS Project ID :** P17-1636

**Matrix :** Drinking Water  
**Report Date :** 4/25/2017

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P17-1636-01	MEC-1-WC-01A	Lead	0.986 J	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/8/17 08:20	4/18/17 15:20
P17-1636-02	MEC-1-WC-02A	Lead	0.530 J	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/8/17 08:21	4/18/17 15:28
P17-1636-03	MEC-1-S-01A	Lead	0.986 J	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/8/17 08:23	4/18/17 16:04
P17-1636-04	MEC-1-S-02A	Lead	ND	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/8/17 08:25	4/18/17 16:08
P17-1636-05	MEC-1-S-03A	Lead	ND	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/8/17 08:27	4/18/17 16:12
P17-1636-06	MEC-1-WC-03A	Lead	ND	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/8/17 08:30	4/18/17 16:16
P17-1636-07	MEC-1-WC-04A	Lead	ND	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/8/17 08:30	4/18/17 16:20
P17-1636-08	MEC-1-S-04A	Lead	1.67 J	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/8/17 08:32	4/18/17 16:31
P17-1636-09	MEC-4-8-FB-A	Lead	ND	ug/L	1	2.00	0.425	15.0 *	SM 3113 B	4/8/17 08:35	4/18/17 16:35

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit  
MDL = Minimum Detection Limit  
MCL = Maximum Contaminant Level  
DF = Dilution Factor  
ND = Analyzed for but not detected  
J = Estimated result  
\* Federal Action Level

All samples are analyzed in accordance with  
New Jersey Department of Environmental  
Protection Protocol

Mark D. Feitelson, Lab. Director